

| | | | |
|--------|----------------|------------------------|----------------|
| Number | 0620-CPR-61104 | Replaces | 0620-CPD-61104 |
| Issued | 2013-09-15 | First issued under CPR | 2013-09-15 |
| | | First issued under CPD | 2011-07-01 |

Certificate of
CONSTANCY OF PERFORMANCE
AVCP 1

Notified Body 0620, Kiwa has determined that

BGS nv

fulfils all provisions concerning the assessment and verification of constancy of performance at system 1 and the performances described in Annex ZA of the standard EN671-1:2012.


Hose reels with semi-rigid hose

Product:

- As stated on page 2 in this Certificate of constancy of performance.

Task
Producer
Factory Production Control
Further testing of Samples

Task
Kiwa
Initial Type Testing
Certification of FPC
Continuous surveillance



Bouke Meekma
Kiwa

This certificate consists of 2 pages.
Publication of the certificate is allowed.

Kiwa Nederland B.V.
Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands

Tel. +31 70 414 44 00
Fax +31 70 414 44 20
info@kiwa.nl
www.kiwa.nl

Producer
BGS nv
Bleyveld 10
3320 Hoegaarden
Belgium
Tel. +32.16 76 08 87
Fax +32.16 76 08 90
e-mail: bgsa@bgs.be

| | | | | | |
|------|---|--------|----------------|------------------------|----------------|
| page | 2 | Number | 0620-CPR-61104 | Replaces | 0620-CPD-61104 |
| | | Issued | 2013-09-15 | First issued under CPR | 2013-09-15 |
| | | | | First issued under CPD | 2011-07-01 |

Notified Body No.0620, Kiwa Nederland B.V.

Certificate of constancy of performance 0620-CPR-61104

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Hose reels with semi-rigid hose

Fixed or swinging fire hose reels with semi-rigid hose with a diameter of 19 mm:

- model HAS20BGS
- model HAS20ZBGS

with a maximum disc diameter of 600 mm and a hose length of 20 meter.

The hose reels are provided with:

- nozzle **KX07-034C-00** with a nominal diameter DN 6,
- semi rigid hose furnished with the marking
HR-EN694:2001 – A – 2 – 19– 1.2MPA (12bar) XQ 20XX (AQ – KIWA)
where the last 2 numbers are standing for the quarter and year of production.

The hose reels are delivered as manual operated and provided with a ball valve.

Fixed or swinging fire hose reels with semi-rigid hose with a diameter of 19 mm:

- model HAS20C-BGS
- model HAS20ZC-BGS

with a maximum disc diameter of 455 mm and a hose length of 20 meter.

The hose reels are provided with:

- nozzle **KX07-034C-00** with a nominal diameter DN 6,
- semi rigid hose furnished with the marking
HR-EN694:2001 – A – 2 – 19– 1.2MPA (12bar) XQ 20XX (AQ – KIWA)
where the last 2 numbers are standing for the quarter and year of production.

The hose reels is delivered as manual operated and provided with a ball valve.

Fixed or swinging fire hose reels with semi-rigid hose with a diameter of 25 mm:

- model HAS30BGS
- model HAS30ZBGS

with a maximum disc diameter of 600 mm and a maximum hose length 30 meter.

The hose reels are provided with:

- nozzle **KX07-034B-00** with a nominal diameter DN 8,
- semi rigid hose furnished with the marking
HR-EN694:2001 – A – 2 – 25 – 1.2MPA (12bar) XQ 20XX (AQ – KIWA)
where the last 2 numbers are standing for the quarter and year of production.

The hose reels are delivered as manual operated and provided with a ball valve.

placed on the market by

**BGS nv
Bleyveld 10
3320 Hoegaarden
Belgium**

| | | | | | |
|------|---|--------|----------------|------------------------|----------------|
| page | 3 | Number | 0620-CPR-61104 | Replaces | 0620-CPD-61104 |
| | | Issued | 2013-09-15 | First issued under CPR | 2013-09-15 |
| | | | | First issued under CPD | 2011-07-01 |

This certificate attests that all provisions concerning the assessment and verification of constancy of performance at system 1+ and the performances described in Annex ZA of the standard


EN671-1:2012

are applied and that

the products fulfil all the prescribed requirements.

This certificate was first issued on 2013/09/01 and will remain valid as long as the harmonised European standard remains valid or the manufacturing conditions in the plant or the factory production control itself are not modified significantly.

Rijswijk, 15 September 2013



Bouke Meekma
Kiwa