Certificate

Certificate of
constancy of performance

0620-CPR-40165-8

Issued	2026-11-01	Replaces	0620-CPR-40165-7
First issued	2002-02-01	Page	1 of 2

PRODUCTS
RvA C 002

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Hose reels with semi-rigid hose

Identification and intended use: Fire safety
Construction product parameters: First aid hose systems-kits
CE marking method(s): ZA.3 of EN 671-1: 2012

placed on the market under the name or trademark of

AFITEC

and produced in the manufacturing plant(s)

ZheJiang - China

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 671-1:2012

under system 1 for the performances set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 01 February 2002 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notiefied product certification body.

Wim van Loon
Managing Director Nederland

Publication of this certificate is allowed.
Advice: consult www.kiwa.com in order to ensure that this certificate is still valid.

202508

Kiwa Nederland B.V.
Sir Winston Churchilllaan 273
Postbus 70
2280 AB RIJSWIJK
Netherlands
Tel. +31 88 998 44 00
NL.Kiwa.Info@kiwa.com
www.kiwa.com

Notified Body Nr. 0063
(ex 0560, 0620, 0956)

AFITEC
Avenue Louise 480
1050 Bruxelles
Belgium
Tel. +32 2 370 24 11
info@afitec.be
www.afitec.be

Certificate of constancy of performance

Hose reels with semi-rigid hose

0620-CPR-40165-8

Technical specification
The following types belong to this certificate:

Hose reels cabinets:
- KX06 – 105A;
- KX06 – 105C;
- KX06 – 105F;
- KX06 – 105H.

Fixed or swinging fire hose reels with semi-rigid hose with a diameter of 19 mm:
- model **HAS501**
- model **HAS503** (swinging)

with a maximum disc diameter of 600 mm and a hose length of **20** meter.
- model **HAS505**

with a maximum disc diameter of 455 mm and a hose length of **20** meter.
- model **HAS506** (swinging)

with a maximum disc diameter of 450 mm and a hose length of **20** meter.

The hose reels are provided with:
- nozzle **KX07-041B-00** with a nominal diameter DN 6,
- semi rigid hose furnished with the marking:
  HR-EN694:2014 – A – 2 – 19– 1.2MPA (12bar) XQ 20XX (AFT–KIWA)
  where the last 2 numbers are standing for the quarter and year of production.

The hose reels is delivered as manual operated and provided with a ball valve.

Fixed or swinging fire hose reels with semi-rigid hose with a diameter of 25 mm:
- model **HAS502**
- model **HAS504** (swinging)

with a maximum disc diameter of 600 mm and a maximum hose length of **30** meter.

The hose reels are provided with:
- nozzle **KX07-041A-00** with a nominal diameter DN 8,
- semi rigid hose furnished with the marking:
  HR-EN694:2014 – A – 2 – 25 – 1.2MPA (12bar) XQ 20XX (AFT–KIWA)
  where the last 2 numbers are standing for the quarter and year of production.

The hose reels is delivered as manual operated and provided with a ball valve.